



- GENERAL NOTES:**
- BACKFILL SOILS AROUND STRUCTURES SHALL BE OF G7 QUALITY OR BETTER (M_n CBR = 15%, COMPACTION 93% MOD AASHTO IN 200 MM LAYERS).
 - FOUNDATION PREPARATION: FOUNDATION SOILS TO BE PREPARED TO ACHIEVE THE MINIMUM SPECIFIED FOUNDATION BEARING PRESSURE.
 - MINIMUM REQUIRED BEARING PRESSURE = 120 kPa TO BE CONFIRMED BEFORE CASTING.

NO.	REV.	DATE	DESCRIPTION	BY	CHKD.	DATE	NO.	REV.	DATE	DESCRIPTION	BY	CHKD.	DATE
1	1/4/18		RAMP SLOPE SPECIFIED	MM	DN	JM							
2	1/4/18		ISSUED FOR CONSTRUCTION	MM	DN	JM							
3	21/11/18		ISSUED FOR APPROVAL	MM	DN	JM							
4	21/11/18		INDEX REVISION **	MM	DN	JM							
D.O.	REV	DATE	INDEX REVISION	BY	CHKD.	DATE	NO.	REV.	DATE	DESCRIPTION	BY	CHKD.	DATE
DESIGN	21/11/18	JM	DM	12/12/18									
APPROVAL	21/11/18	JM	DM	12/12/18									
DESIGN	21/11/18	JM	DM	12/12/18									
APPROVAL	21/11/18	JM	DM	12/12/18									
SCALE													

KUSILE POWER STATION
2018 RADIAL STACKER UPGRADE
NORTH ACCESS RAMP
PLAN AND TYPICAL SECTIONS
DRG. No. K30300098/06-593
366-238334